



TITLE
PW250 Sewage Tank

DRAWN BY C.MORRIS DATE 05/11/2018

CUSTOMER CUSTOMER

NOTE:
All tanks must be fully supported on a flat level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.

DESCRIPTION:
PW250 Swage Tank Un-Insulated

A4

ALL DIMENSIONS IN MM - DO NOT SCALE

| DATE | VERSION | NOTES |
|------------|---------|-------------|
| 05/11/2018 | A | FIRST ISSUE |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

TANK SPECIFICATION :

| | |
|----------------------|--------------------|
| INTERNAL DIMENSIONS | 1000 x 500 x 500mm |
| EXTERNAL DIMENSIONS | 1125 x 625 x 509mm |
| NOM. CAPACITY | 250 Litres |
| DRY WEIGHT | 20 KG |
| INSULATION THICKNESS | NONE |
| WRAS CERT. NUMBER | 131006 |
| MATERIAL | GRP |

SCALE:1:12 SHEET 1 OF 1